

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 614Date: 14.6.2024

It is certified that an inspection team headed by Dr. Pragnan Uslimg
 _____ (Name of Officers
 with designation) from MOIC (Name of
 Department/Office) inspected the G.D. GOENKA PUBLIC SCHOOL, KAILI
MEERUT- HAPUR ROAD, MEERUT (Name & Address of
 the School) on 14.6.24 and found that the _____
G.D. GOENKA PUBLIC SCHOOL (Name of school) has safe
 drinking water facilities for the students and members of staff of the institution and is maintaining
 the hygienic sanitation condition in the school building & the campus as per the norms
 prescribed by the Central/State/U.T Govt.

The above valid for a period of One Year.

Signature with Seal : _____

Name

प्रभारी चिकित्सक आंधिका

Designation

सामु. स्वा. केन्द्र
खरखोदा, मेरठ

To

G.D. GOENKA PUBLIC SCHOOL
KAILI, MEERUT- HAPUR ROAD
MEERUT

(Name & Address of the Institution)

Shiva
 PRINCIPAL
 G.D. GOENKA PUBLIC SCHOOL
 KAILI, MEERUT ROAD
 DIST-MEERUT.



MMT Laboratories Pvt. Ltd.



Testing Today, Transforming Tomorrow....

Add.: Dayal Vihar, Lane No-1, Sikeda Road, Modinagar, Ghaziabad (U.P.)-201204

mmtlaboratories@gmail.com, materialmeasurementlabs@gmail.com | 9045767699, 6398186363

Test Report

Customer: M/S G. D. GOENKA PUBLIC SCHOOL (A UNIT OF G R R EDUCATIONAL AND SOCIAL WELFARE TRUST) KAILI, MEERUT - HAPUR ROAD HAPUR - 245 206	Report No: MMT/20-120624-01 U.L.R No.: TC132632400000068F Format No.: MMT/PL/QF7.8/03 Sample Receipt: 12.06.2024 Sampled by: Customer Analysis start date: 12.06.2024 Analysis End Date: 14.06.2024 Reporting Date: 14.06.2024 Environmental Conditions: Temperature = 25±5°C Humidity = 50±10% RH
Description: Drinking Water	
Sample Qty.: Approx. 1 Litre. in Plastic bottle	

Page-01-01

Test Result

Sr. No.	Parameter	Test Method	Results	Units	Requirement as Per IS: 10500:2012 (Acceptable Limit)	Requirement as Per IS: 10500:2012 (Permissible Limit)
1	pH	IS 3025(P-11)	7.42	-	6.5 to 8.5	No Relaxation
2	Colour	IS 3025(P-4)	<5	Hazen	5Max	15 Max
3	Odour	IS 3025(P-5)	Agreeable	-	-	-
4	Sulphate (as SO4)	IS 3025 (Part 24)	<10	mg/L	200 Max	400 Max
5	Turbidity	IS 3025(P-10)	<1	NTU	1 Max	5 Max
6	Total Hardness, (as CaCO3)	IS 3025 (Part 21)	123	mg/L	200 Max	600 Max
7	Calcium, as Ca	IS 3025 (Part 40)	33	mg/L	75 Max	200 Max
8	Chloride, as Cl	IS 3025 (Part 32)	47	mg/L	250 Max	1000 Max
9	Residual Free Chlorine	IS 3025 (Part 26)	ND(DL-0.1)	mg/L	0.2 Min	1 Min
10	Iron, as Fe	IS 3025 (Part 53)	ND(DL-0.1)	mg/L	1.0 Max	No Relaxation
11	Fluoride, as F	IS 3025 (Part 60)	ND(DL-0.1)	mg/L	1.0 Max	1.5 Max
12	Total Alkalinity (as CaCO3)	IS 3025 (Part 23)	114	mg/L	200 Max	600 Max
13	Total Dissolved Solid	IS 3025 (Part 16)	362	mg/L	500 Max	2000 Max
14	Acidity	IS 3025 (Part 22)	12	mg/L	5 Min	1000 Max
15	Magnesium (as Mg)	IS 3025 (Part 46)	10	mg/L	30 Max	100 Max
16	Specific Conductivity (at 27°C)	IS 3025 (Part 14)	558	µs/cm	-	-
17	Sulphide (as H2S/S)	IS 3025 (Part 29)	ND(DL-0.4)	mg/L	0.05 Max	No Relaxation

Note: N.D.-(Not Detected), D.L.-(Detection Limit)


Remarks: The Sample Confirms to IS: 10500:2012 with Respect to above Tests Only.

G.D. GOENKA PUBLIC SCHOOL
KAILI, MEERUT ROAD
DISTT-MEERUT

*** End of Reports ***



visit us at : www.mmtlabs.com



- This report is valid only for the samples tested in our laboratory.
- The Results given above are relative to the observed values at the time of monitoring and are not to be used for any other purpose than the above test only.
- This report shall be destroyed after one month from the date of issue of certificate.
- Liability of our works is limited to invoiced amount.
- This report can not be used as evidence in a court of law without the written approval of lab.
- Any short of play by the customer with the data of the certificate shall be illegal.
- When the information is supplied by the customer and can affect the validity of results.

MMT LABORATORIES PVT. LTD.
G.D. GOENKA PUBLIC SCHOOL
KAILI, MEERUT ROAD
DISTT-MEERUT